



# PRODUCT PERFORMANCE RATING

Document ID 121120200255-16122743

Issued on 11 December 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 20.11.018**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Liquid Chilling Packages and Heat Pumps / Groupe de production d'eau glacée et pompes à chaleur (LCP-HP)
Product type	Liquid chilling package/ air-cooled/ packaged/ reversible
Brand	KANIONco
Range	A Series Air Source Heat Pump
Product référence	ECOSPAR-M10kW-1N

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
KANION RECORRD	KANION GROUP CO LIMITED	20201211	Macedonia

FEATURE	VALUE	UNIT
<b>ACOUSTICS</b>		
LwO	60.00	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 121120200255-16122743

Issued on 11 December 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 20.11.018**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>A35/W12-7</b>		
Pc	8.20	kW
Pec	2.52	kW
EER	3.25	
Apc Indoor	79.63	kPa

FEATURE	VALUE	UNIT
<b>A7/W40-45</b>		
Ph	10.00	kW
Peh	2.67	kW
COP	3.75	
Aph Indoor	70.43	kPa

FEATURE	VALUE	UNIT
<b>SEER</b>		
SEER	5.98	
$\eta_{sc}$	236.20	



# PRODUCT PERFORMANCE RATING

Document ID 121120200255-16122743

Issued on 11 December 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 20.11.018**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>A35/W23-18</b>		
Pc	9.90	kW
Pec	2.18	kW
EER	4.55	
Apc Indoor	71.02	kPa

FEATURE	VALUE	UNIT
<b>A7/W30-35</b>		
Ph	10.00	kW
Peh	2.02	kW
COP	4.95	
Aph Indoor	70.43	kPa

FEATURE	VALUE	UNIT
<b>A7/W47-55</b>		
Ph	9.50	kW
Peh	3.06	kW
COP	3.10	
Aph Indoor	85.07	kPa



# PRODUCT PERFORMANCE RATING

Document ID 121120200255-16122743

Issued on 11 December 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 20.11.018**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>LRCONTMINH</b>		
Nb Tamont Froid	1	
Nb Taval Froid	1	
Nb Tamont Chauffage	1	
Nb Taval Chauffage	1	

FEATURE	VALUE	UNIT
<b>PSBC</b>		
Psbc	14.00	W

FEATURE	VALUE	UNIT
<b>PSBH</b>		
Psbh	14.00	W

FEATURE	VALUE	UNIT
<b>POFFC</b>		
Poffc	14.00	W



# PRODUCT PERFORMANCE RATING

Document ID 121120200255-16122743

Issued on 11 December 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 20.11.018**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>PTOC</b>		
Ptoc	10.00	W

FEATURE	VALUE	UNIT
<b>PTOH</b>		
Ptoh	24.00	W

FEATURE	VALUE	UNIT
<b>PCKH</b>		
Pckh	0.00	W

FEATURE	VALUE	UNIT
<b>EFFICIENCY AVERAGE W35</b>		
Pdesignh Average W35	9.20	kW
SCOP Average W35	5.19	
ηs Average W35	205.00	



# PRODUCT PERFORMANCE RATING

Document ID 121120200255-16122743

Issued on 11 December 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 20.11.018**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>SOUND AVERAGE W35</b>		
LwO Average W35	60.00	dB(A)

FEATURE	VALUE	UNIT
<b>EFFICIENCY AVERAGE W55</b>		
Pdesignh Average W55	7.70	kW
SCOP Average W55	3.49	
$\eta_s$ Average W55	137.00	

FEATURE	VALUE	UNIT
<b>SOUND AVERAGE W55</b>		
LwO Average W55	60.00	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 121120200255-16122743

Issued on 11 December 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 20.11.018**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
Type of Water Regulation	FW/VO	
Refrigerant	R32	
Main Power Supply	230-1-50	
Control of pump speed	fixed	
Main Intended Market	EU	
Outdoor Heat Exchanger Type	finned tube	
Outdoor Heat Exchanger Dimensions	1126×40×798	
Indoor Heat Exchanger Type	Plate	
Indoor Heat Exchanger Dimension(WxLxH)	87×121×333	
Expansion Device Type	electronic	

FEATURE	VALUE	UNIT
<b>COMPRESSOR_DETAILS</b>		
Compressor motor type	DC inverter	
Compressor Type	Twin Rotary	
Inverter_type	DC Inverter	
Number	1	